

TYPE I and TYPE II HOOD SUBMITTAL CHECKLIST

Required for any Commercial Kitchen Hood Application

Submittal Requirements for current Florida Mechanical Code

This worksheet must be signed and sealed by the Registered Design Professional (RDP) and submitted along with the construction documents for the hood and grease duct under one permit application.

1. Project Address: _____

Name, Firm & Address of RDP completing form: _____

FIRM

NAME

STREET ADDRESS

CITY

STATE

ZIP

SIGNATURE

2. Established Use and Building History:

Is this an existing restaurant, food processing area or food service area? ☐ Yes ☐ No

*If No, provide building permit number for Change of Use/Change of Tenant/ Interior Alteration:

Permit Number: _____

3. Location of Exterior Ductwork and Mechanical Equipment:

a. Is Ductwork or mechanical equipment located outside of building, other than rooftop? ☐ Yes ☐ No

*If yes, as per FBCM 501.3.1, ductwork/mechanical equipment must be a minimum of 10' from the property line.

b. Provide plan and elevation views showing ductwork, duct enclosure, hood, cooking surface, air supply, exhaust system and equipment support, including structural details.

4. Type of Hood (2020 FBCM 507.1):

a. For grease and smoke removal: Type I: _____ Quantity (FSMC 507.2)
(i.e. deep fryer, char broilers, grill, ovens and solid-fuel appliances)

b. For steam, vapor, heat or odor removal: Type II: _____ Quantity
(i.e. steamer, soup kettle, dishwashers)

***Note: Hood should have a permanent, visible label identifying it as a Type II hood.**

c. Is hood for solid-fuel cooking equipment? ☐ Yes* ☐ No

*If yes, a separate exhaust system is required.

5. Type of Material and Gage (FBCM 506.3.1.1, 507.2.3, 507.3.1):

TYPE I HOOD				TYPE II HOOD			
	Type of Material	Minimum Reqs.	Gage Proposed		Type of Material	Minimum Reqs.	Gage Proposed
Duct & Plenum	Galvanized Steel			Duct & Plenum	Refer to SMACNA		
	Stainless Steel	18 gage					
	Factory-built	Provide UL listing					
Hood	Galvanized Steel	18 gage		Hood	Galvanized Steel	22 gage	
	Stainless Steel	20 gage			Stainless Steel	24 gage	
	Note – Black Iron is not in code. Submit Manufacturer & U.L. Listings FBCM 304					Copper	Not less than 24 ounces per square foot

6. Quantity of air exhausted through the hood (FBCM 507):

- a. Canopy hoods shall extend a minimum of 6" beyond cooking surface on all open sides.

Type of hood proposed: ☐ Canopy ☐ Non-canopy

Proposed distance between lip of hood and cooking surface: Canopy _____ ft. 4 ft. maximum allowed Non-canopy _____ ft. 3 ft. maximum allowed

- b. Complete the following for a listed or unlisted hood as applicable:

- I. Listed Hood (see FBCM Section 507.1 exception #1 and #2):

Provide manufacturer's installation instructions and listing documents for listed hoods and grease ducts.

Make and Model Number: _____ Listed CFM: _____

- II. Unlisted Hood – Complete the calculation using the table below:

Quantity of air = Lineal ft. of hood front X CFM from Table below:

$$\underline{\hspace{2cm}} = \underline{\hspace{2cm}} \text{ ft } \times \underline{\hspace{2cm}} \text{ ft. } = \underline{\hspace{2cm}} \text{ CFM}$$

QUANTITY OF AIR LINEAL FT OF HOOD FRONT CFM FROM TABLE BELOW

MINIMUM NET AIRFLOW FOR DIFFERENT TYPES OF UNLISTED HOOD (see 507.5)

Identify the cooking appliances and circle the CFM applied. When any combination of cooking appliances is utilized under a single hood, the highest exhaust rate required by this table shall be used for the entire hood. For hoods that are listed and labeled under UL710 or UL710B, see FBCM 507.1 EX #1 and #2.

Hood Exhaust CFM Table		*CFM / lineal ft. of hood front
1	Extra heavy-duty cooking appliances (non-canopy hood not allowed): all solid-fuel appliances	
2	Heavy-duty cooking appliances: wok, broiler (gas or electric), gas burner range	
3	Medium-duty cooking appliances: conveyor pizza ovens, deep fryer, range (gas or electric), skillet	
4	Light-duty cooking appliances: gas and electric ovens, pasta cookers, steamers	

General Notes:

1. All kitchen hoods and exhaust duct construction plans and this worksheet shall clearly convey and depict Code compliance.
2. Residential appliances to be used and installed in commercial buildings are permitted where approved for use in commercial applications and shall be protected by a Type I or Type II Hood as per the 2020 FBCM. See section 507.1.2.
3. Kitchen hoods shall also be known to comply with the 2020 FSECCC by matching the appropriate Energy Code compliance path with the 2020 FSECCC by using one of the below reference standards:
 - a. 2020 FSECC Section 403.2.8
 - b. ASHRAE 90.1 – 2016 Section 6.5.7.2

7. Makeup Air (508)

- a. Applicant shall provide makeup air approximately equal to the exhaust. _____ CFM.
- b. Makeup air system shall be electronically interlock with the exhaust system, such that the makeup air system will operate when the exhaust is in operation. Provide note on mechanical plans and indicate sheet #_____.
- c. Makeup air shall be provided by a mechanical or gravity means of sufficient capacity. Window and door openings shall not be used for the purpose makeup air.

Fan			Motorized Damper		
Make and Model:		H.P.	Recommended air velocity, 500 fpm		
Static Pressure:	CFM	in at	Duct Area Requirement = CFM/500 fpm	CFM	/500 = ft. ²
Duct Dimension:	Area		Duct Dimension Requirement =		
Air Velocity = CFM/area	CFM	/area = FPM	Eff. Damper Opening =	X	= ft ²

8. Exhaust Duct System (506.3.4): Design Minimum 500 Feet per Minute

a. Applicant shall provide the specified air velocity in exhaust duct.

b. Duct Size _____ in. x _____ in., duct area = _____ in x _____ in. = _____ ft²

Type of Hood	Air Velocity (FPM)	CFM/Duct Area (ft ²)	Proposed Air Velocity
1. Type I Req. 500 to recom. 2500	_____ / _____ = _____	_____ = _____	FPM
Type II Req. Min 500 CFM	_____ / _____ = _____	_____ = _____	FPM
2. Static Pressure Loss Duct _____ in. + grease filter/extractor _____ in. + other _____ in. = Total _____ in. of H ² O			
3. Fan and motor shall be of sufficient capacity to provide the required air movement. Fan motor shall not be installed within ducts or under hood. Fan make and model _____ HP _____ Static Pressure _____ in. at _____ CFM			
Note: If using a listed duct wrap, provide manufactures installation instructions and listing documents: _____			

9. Exhaust Outlet Location (506.3.13)

Exhaust Outlet Location		Minimum Required	Proposed
Exhaust outlet shall terminate above roof	Type I Type II		
Distance from same or adjacent building	Type I Type II		
Distance from above adjoining grade	Type I Type II		
Distance from property line	Type I Type II		
Distance from windows and doors	Type I Type II		
Distance from mechanical air intake	Type I Type II		

10. Duct Slop and cleanout Access (506.3.7, 506.3.8, 506.3.9):

- a. Horizontal duct up to 75' long: Minimum Slope $\frac{1}{4}$ in./ft. Proposed: _____ in./ft.
Horizontal duct more than 75' long: Minimum Slope 1 in./ft. Proposed: _____ in./ft.
Total Proposed: _____ in./ft.
- b. Tight-fitting cleanout doors shall be provided at every change in ductwork direction.

11. Duct Enclosure (506.3.11) (507.2.7 Hoods within ceiling cannot use 506.3.11.2):

- a. Ducts penetrating ceiling, wall or floor shall be enclosed in a duct enclosure as per sections 506.3.11.1, 506.3.11.2 and 506.3.11.3 Provide manufacturer installation and test documents). Shaft enclosures shall unprotected openings are permitted as per FBCM Table 705.8.

Number of Stories	Min Fire-Resistive Const. Of Enclosure	Proposed	Proposed Material & Construction
Less than 4	1 hour	hr.	
4 or more	2 hour	hr.	

Provide manufacturer's installation instructions and listing documents for exceptions

- a. Where no enclosure is provided, ducts shall have a clearance from combustible construction of not less than 18 inches. (506.3.11 and 506.3.6) Provided: _____ in.
- b. Duct enclosures shall be sealed around the duct at the point of penetration and vented to the exterior through a weather-protected opening.
- c. Duct enclosures shall serve only one kitchen exhaust duct (see multiple hood venting for exception)
- d. Tight-fitting hinged access door shall be provided at each cleanout. Access enclosure doors shall have a fire-resistance rating equal to the enclosure. An approved sign shall be placed on the access door:
"ACCESS PANEL. DO NOT OBSTRUCT."

12. Multiple Hood Venting (506.3.5)

- a. Number of hoods vented by a single duct system: Proposed _____
A single-duct system may serve more than one hood located in the same story of the building, provide that the interconnecting ducts do not penetrate any fire resistance rated construction and are located in adjoining rooms; and the grease duct system does not serve a solid fuel-fired appliance.
- b. An unlisted hood outlet shall serve not more than a 12-foot section of hood.

13. Additional Information – Type I Hood Only (507.2.5)(507.2.6)(507.2.8)(507.2.9)

- a. Grease filters shall be installed at a minimum 45 degrees angle and equipped with drip tray and gutter beneath lower edge of filters. Proposed: _____ degrees
- b. Distance between lowest edge of grease filters and cooking surface of:
Grill, fryer, exposed flame shall not be less than 2 ft. Proposed: _____ ft.
Exposed charcoal, charbroil shall not be less than 3 ft. Proposed: _____ ft.
- c. Type I hood shall have clearance from construction of:

UNPROTECTED (Combustible Construction)	EXCEPTION
Hood min. required clearance of 18 in Proposed: _____ in.	1) Clearance shall not be required from gypsum wallboard attached to noncombustible structures provided that a smooth, cleanable, nonabsorbent and noncombustible material is installed between the hood and the gypsum or cementitious wallboard extending not less than 18 inches in all directions from the hood. 2) Hoods listed and labeled for reduce clearance UL710.

- a. Grease gutters shall drain to an approved collection receptacle that is fabricated, designed and installed to allow access for cleaning.
- b. Hoods less than 12 inches from ceilings or walls shall be flashed solidly.
- c. All joints and seams shall be made with continuous liquid-tight weld or braze made of the external surface of the duct system. Vibration insulation connector may be used provided it consists of noncombustible packing in a metal sleeve joint. (506.3.2, 506.3.2.4) Joints shall be smooth and accessible for inspection (506.3.2.5).
- d. Exhaust fans used for discharging grease exhaust shall be positioned so that the discharge will not impinge on the roof. The fan shall provided with an adequate drain opening at the lowest point to permit drainage of grease to a suitable collection device. (506.5.3).
- e. Up-blast fans serving Type I hoods and installed in a vertical or horizontal position shall be hinged, supplied with a flexible weatherproof electrical cable to permit inspections and cleaning and shall be equipped with a means to limit swing of the fan on its hinge. Ductwork shall extend 18 inches or more above roof surface. Exhaust outlet shall be not less than 40 inches above the roof surface (506.3.13) (506.5.3)
- f. Fire Suppression System shall be per NFPA Fire Code. Provide automatic shutoff for make-up air, exhaust system and appliances when suppression system is activated. Dependent on suppression agent and manufacture's requirements. Separate permit is required.
- g. Performance test certificate of the hood system shall be provided to owner before final approval. Test shall verify property operation, the rate of exhaust makeup air, capture and containment performance of the exhaust at normal operating conditions. (507.6)
- ..